

BRYAN BOILERS

HE - AB - GP
DATE: 11/01/06
NEW

Originators of the "Flexible Water Tube" design

GORDON-PIATT BASE BURNER DATA "HE-AB" SERIES BOILERS NATURAL GAS

BOILER MODEL	INPUT MBH	BASE BURNER MODEL (1)	COMBUSTION CONTROL MODEL/SCANNER (2)	IGNITION MEANS (3)	MOTOR DATA (4)	FIRING SYSTEM	GAS TRAIN DATA		
							TRAIN SIZE NPT (5)	STANDARD PRESS IN. W.C./PSI	
	MIN	MAX							
HE-AB 90	900	SR6.1 - **	RM7895C/UV	GP	1/3	ON/OFF	1-1/2"	7.0"	14.0"
HE-AB 120	1200	SR6.2 - **	RM7895C/UV	GP	1/3	ON/OFF	1-1/4"	7.0"	14.0"
HE-AB 150	1500	SR8.9 - **	RM7895C/UV	GP	1/2	ON/OFF	1-1/2"	7.0"	14.0"
HE-AB 200	2000	SR8.0 - **	RM7895C/UV	GP	3/4	ON/OFF	1-1/2"-2"	7.0"	14.0"
HE-AB 250	2500	SR8.1 - **	RM7895C/UV	GP	1	ON/OFF	1-1/2"-2"	7.0"	14.0"
HE-AB 300	3000	SR8.3 - **	RM7895C/UV	GP	2	ON/OFF	3"	7.0"	14.0"

STANDARD GAS TRAIN COMPONENTS		
COMPONENT	AB 90 TO AB200	AB 250 and 300
Manual Shutoff Valve (point of field connection)	STD.	STD.
Gas Pressure Regulator	STD.	STD.
Main Oper. Gas Valve - Diaphragm type	STD.	STD.
Main Oper. Gas Valve - Motorized type	OPT.	STD.
Auxiliary Oper. Gas Valve - Solenoid type	STD.	STD.
Low Gas Pressure Switch	OPT.	OPT.
High Gas Pressure Switch	OPT.	OPT.
Manual Checking Shutoff Gas Valve	STD.	STD.
STANDARD OIL COMPONENTS		
Dual shutoff valves	STD.	STD.

- ABBREVIATIONS:
- (1)** Insert: "G" - Gas
 - (2) Combustion Control:
Model - RM7895C
Scanner - "UV" = Ultra Violet
 - (3) Ignition means:
"GP" - Gas Pilot
 - (4) Motor Voltage: 60 Hz - Motor RPM: 3450 RPM
1/3 HP to 1 HP = 120/1 Ph
1 1/2 HP & Larger = 208-240-480/3 Ph (please specify)
 - (5) Gas Train: Main gas shutoff valve and gas pressure regulator are first size; gas operating and auxiliary valves are second.



NOTES >>>

1. Burner capacities listed for elevations up to 2,000 ft. For higher elevations, consult local Bryan Boilers sales office.
2. Gas rating based on natural gas with heating value of 1000 Btu per cubic foot and specific gravity of .60. Gas burners for other gases are available, consult local Bryan Boilers sales office.



783 N. Chili Ave., Peru, Indiana 46970
Telephone: (765) 473-6651
Fax: (765) 473-3074
E-Mail: bryanboilers@iquest.net
Internet: www.bryanboilers.com