


NOTES:

- 1.) ALL FITTINGS TO BE 150# MALLEABLE IRON FOR SECT IV BOILERS.
ALL FITTINGS TO BE 300# MALLEABLE IRON FOR SECT I BOILERS.
- 2.) ALL PIPING TO BE SCH. 40 FOR SECT IV BOILERS.
ALL PIPING TO BE SCH. 80 FOR SECT I BOILERS.
- 3.) BY-PASS LINE TO BE PIPED ABOVE FOR RW SERIES.
ALL PIPING, FITTINGS AND VALVES SELECTED ARE TO MEET OR EXCEED THE APPLICABLE ASME BOILER PRESSURE CODE AND ASME PIPING CODE

ITEM	QTY	DESCRIPTION
1	—	GATE VALVE
2	—	SWING CHECK VALVE
3	—	GLOBE VALVE
4	—	STRAINER
5	—	SOLENOID FEED VALVE MODEL
6	—	MOD. FEED VALVE MODEL
7	—	GATE VALVE

		<h2 style="margin: 0;">BRYAN STEAM</h2> <p style="margin: 0;">783 North Chili Avenue Peru, IN 46970</p>			
		<p>DWG. TITLE:</p> <h3 style="margin: 0;">TYPICAL PIPING DIAGRAM FOR MODULATING OR SOLENOID FEED VALVE WITH BYPASS</h3>			
REVISION NO.	DATE:	SCALE:	DISK:	DWG. NO.:	FORM. NO.:
2	8/10/99	NONE	FS	A20002	2282